

Certificate
ET-0431-25

Issued	14.03.2025	Replaces	-
Valid until	13.03.2030	First issue	14.03.2025

Product certificate

Kiwa Estonia OÜ has granted a product certificate to attest that the product

Corrugated double wall cable conduits for buried underground applications

placed on the market by

Pipelife Eesti AS

Põrguvälja tee 4, Lehmja küla, 75306 Rae vald, Harju maakond, Estonia

and produced in the factory

Pipelife Eesti AS

Põrguvälja tee 4, Lehmja küla, 75306 Rae vald, Harju maakond, Estonia

has following performances

Nominal outside diameter (mm)	Resistance to compression		Resistance to impact (class)	Resistance to bending
	Minimum force (N)	Type		
50 - 160	450	450	L	Pliable
50 - 160	450	450	N	Pliable
50 - 160	450	450	L	Rigid
50 - 160	450	450	N	Rigid
50 - 160	750	750	L	Rigid
50 - 160	750	750	N	Rigid
110	1250	750	N	Rigid

The company has a working product management system that has been implemented in accordance with the requirements of the standard **EN 50626-1:2023**

The manufacturer is testing the samples taken at the factory in accordance with prescribed test plan. Kiwa Estonia OÜ has performed type testing, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment, and approval of the factory production control.

The certificate is valid until the manufacturing conditions in the factory of the FPC itself are not modified significantly. The validity of the certificate can be checked on the Internet at www.kiwa.com/ee.


Toomas Reha
Head of conformity assessment department



Kiwa Estonia OÜ
Mäealuse 2/4
12618 Tallinn, Eesti
T +372 6 599 470
Estonia@kiwa.com
www.kiwa.com/ee/et/